



CLIENT INFORMATION

Floorwax
Attention: Sipho Khazi

East London

SCIENTIFIC CONSULTANTS IN EMISSIONS FROM BUILDING PRODUCTS

Emission Test Certificate

Lab No : 3809A

TEST INFORMATION Test Method ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions From Indoor Material/Products"

DATE ISSUED 2013/11/20 **DATE RECEIVED** 2013/11/08 **DATE TESTED** 2013/11/14

SAMPLE INFORMATION

SAMPLE ID Industrial Flooring (MIF)
SUPPLIER FloorWorx

ENVIRONMENTAL DATA SUMMARY

Material Type Floor Tiles
Speciment size 0.004 m2
Chamber volume 0.02 m3
Material loading 0.2 m2 sample /m3 air
Chamber Temperature 27 deg C
RH 80 %
Air flow rate 0.5 L/min
Air Exchange rate 1.5 (h-1)

EMISSION DATA FOR TOTAL VOLATILE ORGANIC COMPOUNDS

Green Building Specifications	Results
< 0.5 mg/m2/hr	0.04 mg/m2/hour

Authorised Signatory :

W Havenga
Laboratory Manager
2013/11/20

Page 2 of 3

DISCLAIMER: The results only relate to the test items provided. This report may not be reproduced, except in full, without the prior written approval of the laboratory.